

MANUFACTURERS Declaration

Manufacturer: **Ryterna UAB,**
Savanorių av. 404 d,
LT - 50301 KAUNAS,
Lithuania

Ryterna sectional doors' Sound Reduction Index according to ISO 10140-2 is $R_w=25$ dB

According to test results provided on 1 March 2012 at KTU Architecture and
Construction Institute (accreditation No. LA.01.031), Test protocol No. 019-2SSF/12A

Kaunas , Lithuania

March, 2012

Vytas Rinkevičius
(Director)

